



NOTES:

AUXILIARY CTs ARE INCLUDED IN DRMCC SUPPLY
 VTs AND MAIN CTs ARE EXCLUDED, TO BE SUPPLIED BY OTHERS

DIGITAL INPUTS MAY BE CUSTOMISED USING SOFTWARE PROVIDED - SEE MANUAL FOR DETAILS

ALL RELAY OUTPUTS ARE CONFIGURABLE - SEE MANUAL

RATED -40 TO +85°C
 INTERNAL ANALOG (AMBIENT TEMP) -40 TO +110°C UPDATED EVERY 1.4 SECS
 RS-485: DNP 3.00 - LEVEL 1, REPORT BY EXCEPTION SUBSET
 OPTIONS: 9 x SOFTWARE TYPES (FOR CT & VT CONFIGERATIONS)

MODULE DEPTH 95mm (FROM BOTTOM OF RAIL TO TOP OF COVER)

SETTING: 4 x ROTARY SWITCHES NUMBERED 1-4
 SETTING: RS-485 LINKS JP2, JP3

REFERENCE: SICM2B USER REFERENCE MANUAL REVISION B (28.05.01)

REV	DESCRIPTION	COMPILED	APPROVED	DATE	DIMENSIONS ARE IN MILLIMETERS	 A3 SCALE 1:1	CONTROL CIRCUIT DIAGRAM DRMCC - T2 SICM2B MODULE		134-0113E PAGE 1 OF 1
O	ORIGINAL ISSUE	ALR	MW	17.08.01	THIS DRAWING IS NOT TO BE COPIED NOR THE INFORMATION HEREON DIVULGED TO ANY THIRD PARTY OR USED FOR THE MAKING OF APPARATUS WITHOUT THE WRITTEN PERMISSION OF DYNAMIC RATINGS PTY LTD ABN 81 083 456 044				
A	REVISED FOR T2 (DRAWING No. CHANGED)	BOZ		12.02.02					
B	MODIFIED THE SCREEN CONNECTION OF SCREEN CABLE	BOZ		28.05.02					